



WATER QUALITY MONITORING UNIT
AMRIT BHAWAN, VINAY MARG, CHANAKYAPURI
QUALITY CONTROL & TECHNICAL AUDIT CELL
NEW DELHI MUNICIPAL COUNCIL
ISO 9001-2015 CERTIFIED

SAMPLE NOT COLLECTED
BY UNIT STAFF

1. Name & Address of Sender:- Principal, St. Columba's School
2. Date of Receiving/Collection:- 18/09/2026
3. Sample No.:- 9326-9329
4. Sealed Sample (Yes/No):- Yes.

DRINKING WATER TESTING REPORT

TEST-RESULTS

Sr. No.	Location, Date & Time of Sample Collection Site	Colour (Pt-Co Scale)	Taste & Odour	Turbidity (NTU)	P ^H	Total Hardness (as CaCO ₃) (Mg/L)	TDS (Mg/L)	Iron (as Fe) (Mg/L)	Chloride (as Cl) (Mg/L)	Residual free Chlorine (Mg/L)	Coliform org. MPN / (100 ML)	E.Coli MPN / 100 ML
1.	St. School	5	Agreeable	0.6	7.8	62	95	NA	24	NIL	NIL	—
2.	St. School	<5	Agreeable	0.4	7.9	36	54	NA	14	NIL	NIL	—
3.	Middle School	5	Agreeable	0.3	7.7	88	135	NA	34	NIL	NIL	—
4.	Middle School Ground	5	Agreeable	0.3	7.7	88	126	NA	36	NIL	NIL	—
5.												
BIS: 10500 2012	Acceptable Limits	max 05	Agreeable	1 max.	6.5 To 8.5	200 max.	500 max.	0.3 max.	250 max.	0.2 min.	NIL	NIL
	Permissible Limits (in the absence of alternate source.)	15	Agreeable	5	No relaxation	600	2000	No relaxation	1000	1	NIL	NIL

Remarks: With respect to above tests, all the above water samples except Sr. No. _____ can/cannot be considered fit for drinking purposes. However minimum residual free chlorine 0.2 Mg/L should be done to avoid contamination.

18/09/2026
Bacteriologist
Chemist/Lab. Technician

21-09-2026
Lab. Technician/Asstte.

- Note:-**
- 1) water samples will be destroyed after testing unless otherwise specified by party.
 - 2) If the sample is not collected by our WQMU staff, the sender/party will be responsible for any wrong, incomplete or misleading information given by him.
 - 3) This test report is not valid for any legal proceeding.